



ADDENDUM NO. 1

TO THE INVITATION TO BID DOCUMENTS
FOR
Orchard Home Waterline Extension
WO87345

August 15, 2023

This addendum provides changes to the Contract Documents for the above-titled Project to be considered by each Bidder. This addendum shall be included with the Bid and, when executing the Contract, will be part thereof. Any changes to the Contract Documents made by this addendum shall become a part of the Contract Documents, and all unchanged items shall remain in full force. It is the responsibility of all Bidders to conform to this addendum.

QUESTIONS AND CLARIFICATIONS

Item No.	Question	Response or Clarification
1-01	On the Form of Bid, item #13 includes a dry-tap water service but there are no water service installations shown on the plans?	Item #13 on the Form of Bid is to capture a price for potential water services that adjacent property owners may request during construction. Assume a 30-foot length of copper service line is necessary for this item.
1-02	On sheet C2, station 12+91.4 shows the installation of an air release valve, but there is no corresponding note #8?	See addendum item A-01 below, this air release valve and the work associated with it has been removed.
1-03	On sheet C2, station 10+18.0 in the plan view, it shows connecting to existing 8-inch ductile iron. However, in the profile view it shows connecting to existing 12-inch water?	See addendum item A-02 below, this connection is to existing 8-inch ductile iron pipe, not 12-inch.


ADDENDUM ITEMS

Item No.	Specification or Drawing Number	Location and Description of Change
A-01	Volume II, sheet C2, station 12+91.4	Remove air release valve from this location (note 8) and the work associated with it (note 3).
A-02	Volume II, sheet C2, station 10+18.0	<u>In the profile view only</u> , change the text of existing 12- inch water to existing 8-inch water.
A-03	Volume I, General Specifications	Add the attached <u>Special Provisions to the General Specifications</u> at the end of the Special Specifications section.

ACKNOWLEDGEMENT: All Bidders shall acknowledge receipt and acceptance of this Addendum on the Bid Form. Bids submitted without acknowledgment may be considered informal.

End of Addendum No. 1

BOARD OF WATER COMMISSIONERS
CITY OF MEDFORD, OREGON

By:  _____

Brad Taylor, General Manager

Receipt acknowledged and conditions agreed to this _____ day of _____, 2023.

Bidder: _____

By: _____

(Signature)

(Print Name)

SPECIAL PROVISIONS to GENERAL SPECIFICATIONS

SPECIAL PROVISION to GENERAL SPECIFICATION 1-3-3 PROVISION FOR TRAFFIC

DELETE the last paragraph of General Specification 1-3-3 Provision for Traffic and REPLACE with:

Payment for work described in General Specification 1-3-3 Provision for Traffic and General Specification 1-5-15 Barricades, Warning Signs and Flagmen shall be paid for as included in the Bid Schedule under "Accommodations for Public Traffic and Work Zone Traffic Control".

SPECIAL PROVISION to GENERAL SPECIFICATION 1-5-14 PUBLIC SAFETY AND CONVENIENCE

ADD to the end of General Specification 1-5-14 Public Safety and Convenience:

The Contractor shall communicate proposed temporary closures of driveways and roadways to the Medford Water inspector and project manager and to the affected public and residents along the project a minimum of 48 hours in advance. Private driveways shall not remain blocked for more than one hour without advance concurrence of a longer closure time by Medford Water.

The Contractor shall at all times provide provisions for emergency vehicles to traverse through portions of roadways closed for construction.

The Contractor shall provide provisions for dead end roadways (Westwood Drive) to remain open to public travel in at least a single travel lane.

No equipment or materials shall be allowed to be stored within the public or private street right-of-way outside of working hours without previous approval by Medford Water and the agency holding jurisdiction over the roadway right-of-way.

SPECIAL PROVISION to GENERAL SPECIFICATION 1-5-15 BARRICADES, WARNING SIGNS AND FLAGMEN

In the first paragraph of General Specification 1-5-15 Barricades, Warning Signs and Flagmen, DELETE "Barricades shall be of substantial construction and shall be painted black and white in diagonal stripes to increase their visibility at night." And REPLACE with:

All traffic control measures shall be in accordance with the requirements in the most recent Manual on Uniform Traffic Control Devices (MUTCD).

After the first paragraph of General Specification 1-5-15 Barricades, Warning Signs and Flagmen, ADD:

Contractor shall choose construction methods and equipment such that public access along Westwood Drive is safely maintained at all times. Limit the length of open excavation to the maximum length (approximately 30 feet) necessary to install one segment of pipe. Provide appropriate traffic controls and flaggers as needed to maintain a safe single lane around the excavation. Provisions for immediate opening of the roadway for emergency vehicles shall be provided.

At a minimum a safe travel lane of 10' width plus a 2' offset from the travel lane to the trench and appropriate barricades shall be provided.

Irrespective of required approvals and interpretations of traffic control plans from jurisdictional agencies, Contractor shall address any safety and public convenience concerns noted by Medford Water, notwithstanding that all responsibility for such remains with the Contractor.